



# SWEDISH TYPE APPROVAL 31631 WITH DECISION ON PRODUCTION CONTROL

## Holder: Scandinavian Brand Group Aps

Østerbrogade 202, DK-2100 Copenhagen, Denmark

Phone: +45 28351179

E-mail: [bj@badstil.dk](mailto:bj@badstil.dk)

Homepage: [www.pulcher.dk](http://www.pulcher.dk)

## Mechanical mixers

### Product description

Single-lever built-in mixers, made of stainless steel. The mixers are available with different finishes.

### Intended use

Mixer for hot and cold tap water intended to be used for shower.

### Scope

Classwell: C16 and C17



### Approval

The products meet the requirements of Chapter 8, Section 4, of the "Planning and Building Act" (PBA) regarding the technical characteristics of construction works, "3. Protection with regard to hygiene, health and the environment", depending on, that what is stated in this approval is followed. The products are approved according to the following section(s) of "Boverket's Building Regulations" (BBR):

Construction products with assessed properties	1:4
Tap water installations	6:62
Tap water flow	6:623, 1 <sup>st</sup> sentence
Back flow	6:624
Design	6:625, paragraph 1 and 4

### Marking

Marking must be affixed on the product or, if there are special reasons, on the packaging or the delivery note. Marking shall indicate the following information:

Holder:	Scandinavian Brand Group Aps
Product name, and relevant article number:	Product name (article number)
Production site:	Applicable manufacturer or ID code
Traceability to the production:	(e.g. yyyy-mm-dd or batchnumber)
Information about requirements or class, if relevant:	(e.g. flow rate)
The registered trademark of Boverket No 241 217:	
Certification Body:	Kiwa Certification AB 
Accreditation number:	1913
Type Approval No:	31631
Inspection Body:	Danish Technological Institute (DTI)

CERTIFIKAT

## Kiwa Certification AB

Campus Gräsvik 1  
SE-371 75 Karlskrona  
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

[se.bygg@kiwa.com](mailto:se.bygg@kiwa.com)

[www.kiwa.se](http://www.kiwa.se)



**Production site:** PCW14

**Control**

The manufacturers' continuing internal control is combined with surveillance inspections conducted by an accredited Inspection Body.

Inspection Body: **DTI**

Inspection agreement: **157 with Appendix A, dated 2023-06-08.**

Factory production control shall be carried out in accordance with the current instructions for control.

During inspection at the construction site, the building proprietor must verify the identity of the product by means of the marking. Furthermore, the building proprietor must ensure that the correct products are delivered and that they are installed in accordance with the manufacturer's instructions in the accompanying documents. It must also be verified that the product is accompanied by a manufacturer's declaration that certifies that production has been carried out in accordance with the documents that formed the basis for this type approval.

The validity of the Swedish Type Approval also implies that the factory production control is carried out according to the current agreement and that the holder annually fulfils the requirement in "Boverket's regulations and general recommendations for type approval", BFS 2013:6, § 5 (TYP 7), on continuing internal control. The holder shall annually, at the latest on the 15th of December, report to Kiwa Certification AB at the e-mail address [se.annualreporting@kiwa.com](mailto:se.annualreporting@kiwa.com) about continuing surveillance.

**Associated documents**

Installation instructions: Classwell C16 and C17 by Pulcher

**The assessment basis for the approval**

Test reports: 2024:01076 by Sintef

Assessment report 31631-1 dated 2025-02-24 by Kiwa Certification AB.

**Comments**

Products are verified according to EN 817:2008 and NKB Product Rules No. 4.

The mixers meets the requirement for acoustic class I according to EN3822.

The Type approval is valid provided that the product shall neither be CE marked according to the Construction Product Regulation (EU) No 305/2011 (CPR), nor has it been suspended or withdrawn by Kiwa Certification AB.

Date of decision: 2025-02-24

Current version: 31631-1

Valid until: 2030-02-23



**Fredrik Sandberg**

Business Manager, Building & Energy

Kiwa Certification AB